



Peter Chopelas, PE

Engineering & Design Services

307 N. Olympic Ave, Suite 208

Arlington, WA 98223

(360) 653-4615

Chopelasandassociates@gmail.com

February 26, 2021

Creative Concrete Products
115 Lind Street
Mount Vernon, WA 98273

Subject: Duraskirt™ manufactured home perimeter skirt wall system HUD compliance


The subject Duraskirt™ manufactured home perimeter skirt wall system was review for compliance with the current HUD handbook “Permanent Foundation Guild for Manufactured Housing” publication HUD-7584.

It was found that the Duraskirt system meets all of the requirements for foundation Type C. These are systems that structurally support and anchor the home at the chassis, per section 100-2. Since perimeter walls may or not be used to structurally support or anchor the home, the Duraskirt™ will meet HUD guidelines. Furthermore it is composed of rot resistant materials (concrete) and contains screened ventilation openings to meet the other requirements for Exterior perimeter foundations walls.

The design and strength of the Duraskirt™ system has generous safety factors for the applied loads of wind and seismic forces, plus the back fill loads against the skirting if installed per the manufacturer’s recommendations.

If you have any questions or are in need of further assistance, please feel free to call.

Sincerely,



Peter Chopelas PE