



BBACA ENGINEERING

HOME & BUILDING INSPECTION SPECIALISTS

2401 E. Taxidea Way
Phoenix, AZ. 85048
e-mail: ralph@bbacaengineering.com
website: www.bbacaengineering.com

Phone Number: 480-706-6222
FAX Number: 480-706-9330

Date: July 27, 2024

Client: DURASKIRT
PO Box 279
Mount Vernon, WA 98273

Project Description: Duraskirt™ Manufactured Home Perimeter Skirting Wall System HUD compliance
Project Report: 240126-1054E

The subject Duraskirt™ manufactured home perimeter skirt wall system was review for compliance with the current HUD handbook "Permanent Foundation Guild for Manufactured Housing" publication HUD-7584.

It was found that the Duraskirt system meets all the requirements for foundation Type C. These are systems that structurally support and anchor the home at the chassis, per section 100-2. Since perimeter walls may or not be used to structurally support or anchor the home, the Duraskirt™ will meet HUD guidelines. Furthermore, it is composed of rot resistant materials (concrete) and contains screened ventilation openings to meet the other requirements for Exterior perimeter foundations walls.

The design and strength of the Duraskirt™ system has generous safety factors for the applied loads of wind and seismic forces, plus the back fill loads against the skirting if installed per the manufacturer's recommendations.

If you have any questions or are in need of further assistance, please feel free to call.

Sincerely,



Approved by Glen L. Hunt III, P.E